



Office of Executive Engineer
Sub Divisional Engineer,
Water Supply & Sanitation Sub Division No.1 Sri Anandpur Sahib

E.mail : Xen_Ropar@Yahoo.com

Tel. No. 01887-297171

The


The Principal,
Mighty Khalsa International School,
Sri Anandpur Sahib.

No. 667 Dated: 12-9-2022.

Subject:- Regarding Water and Sewerage Condition.

It is Certified that the water sample is found potable as per the report of Block water testing laboratory, DWSS Sri Anandpur Sahib Punjab (with respected to IS code 10500) drinking water sample dated 06-09-2022 and sewerage connection is also provided to the school by this department.

DA/Above


Sub Divisional Engineer,
W/S & Sanitation Sub Divn.No.1,
Sri Anandpur Sahib.

BLOCK WATER TESTING LABORATORY, ANANDPUR SAHIB

Department of Water Supply and Sanitation, VIP Road, Shri Anandpur Sahib
bwtlaps@gmail.com

TEST REPORT

Name & Address of Customer : Director Mighty Khalsa International School Sri Anandpur Sahib Director Mighty Khalsa International School Sri Anandpur Sahib	Customer Reference No. No : MKIS/2022/912 Dated : 06/09/2022
	Sample Submitted by Mr Harminder Singh
	Date of Sample Receipt 07/09/2022
	Analysis Starting Date 07/09/2022
	Analysis completion Date 08/09/2022

Discipline : Chemical Testing

Group: Water

Test Report No.: BWTLAS/2223/00362

Date of Issue : 10/09/2022

Registration no.: BWTLAS/REG2223/00444

Condition of Sample : Unsealed

Source : NA

Quantity/Type of Bottle: 1000 ml / Transparent Plastic Bottle

Scheme : NA

Location/Depth : School Tap Water / NA

Village : Sahota

Habitation : Sahota

Block: Anandpur Sahib

District : Roopnagar

Latitude : NA


Longitude: NA

Sample Type: Water

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.01	6.5-8.5	No Relaxation	-	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	<5	5	15	Hazen	IS 3025 (Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable	-	IS 3025 (Part 5-2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Disagreeable	-	IS 3025 (Part 8-1984) (RA 2017)
5	TDS	133	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	2.7	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	52	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	120	200	600	mg/l	IS 3025 (Part 21-2019) EDTA Method
9	Calcium	33.6	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	8.7	30	100	mg/l	APHA (23rd Ed. 2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	14	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. * Value not available or test not performed for this parameter.


Mr. Avtar Krishan
Chemist/Analyst
Authorized Signatory
For, Block Water Testing Laboratory,
Anandpur Sahib

End of the Test Report

BLOCK WATER TESTING LABORATORY, ANANDPUR SAHIB

Department of Water Supply and Sanitation, VIP Road, Shri Anandpur Sahib
bwtlaps@gmail.com

To,

Director Mighty Khalsa International School Sri Anandpur Sahib
Director Mighty Khalsa International School Sri Anandpur Sahib


No.: BWTLAS/2223/00362 Dated : 10/09/2022

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. MKIS/2022/912 Dated: 06/09/2022

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 07/09/2022. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Anandpur Sahib

D/A : Test Report



**Authorized Signatory
For, Block Water Testing Laboratory,
Anandpur Sahib**